

PROFIBUS Configuration for Moxa MGate 5101-PBM-MN and Siemens S7-1200

Moxa Technical Support Team
support@moxa.com

Contents

- 1. Introduction 2
- 2. Applicable Products 2
- 3. System Requirements 2
- 4. System Overview 3
- 5. PLC Configuration 4
 - 5.1. Create a new project 4
 - 5.2. Create a PROFIBUS slave device 5
- 6. Moxa’s PROFIBUS device configuration 8
 - 6.1. Install the GSD file 8
 - 6.2. Device configuration with MGate Manager 9
- 7. Communication Test 11
 - 7.1. Execute Modbus Poll as the Modbus TCP master device 11
 - 7.2. Modifying and monitoring I/O data 12

© 2013 Moxa Inc.

Released on January 3, 2013

About Moxa

Moxa manufactures one of the world’s leading brands of device networking solutions. Products include serial boards, USB-to-serial hubs, media converters, device servers, embedded computers, Ethernet I/O servers, terminal servers, Modbus gateways, industrial switches, and Ethernet-to-fiber converters. Our products are key components of many networking applications, including industrial automation, manufacturing, POS, and medical treatment facilities.

How to Contact Moxa

Tel: +886-2-8919-1230 Web: www.moxa.com
Fax: +886-2-8919-1231 Email: info@moxa.com



1. Introduction

This tech note describes how to configure a Moxa MGate device as a PROFIBUS DP master to connect to a Siemens S7-1200 PLC as a PROFIBUS DP slave. We illustrate the procedure by configuring data for one word input and one word output.

2. Applicable Products



Product Line	Model Name
MGate 5000 series	MGate 5101-PBM-MN
	MGate 5101I-PBM-MN
	MGate 5101-PBM-MN -T
	MGate 5101I-PBM-MN -T

3. System Requirements

Description	Model/File Name	Version
Siemens S7-1200 PLC	CPU 1212C AC/DC/Rly	2.0
Siemens S7-1200 PROFIBUS module	CM 1242-5	1.0
Siemens PLC programming software	TIA Portal V11	
Moxa PROFIBUS DP master to Modbus TCP gateway	MGate 5101-PBM-MN	1.0
GSD file for Siemens S7-1200 DP slave	SI01818E.GSD	1.0
Software utility to configure Moxa device	MGate Manager	1.6
Modbus TCP master software	Modbus Poll	3.60a

4. System Overview



In this document, the MGate 5101-PBM-MN is used as an example. The system architecture is shown below.



5. PLC Configuration

5.1. Create a new project


5.1.1. Start TIA Portal V11 and create a new project by selecting **Project** → **New**. and then assign a name to this project. In this example, we use "Project01" as the project name.



Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200


5.2. Create a PROFIBUS slave device

5.2.1. Double click on Devices & networks and select the proper device in the Catalog window. In this example, we choose the S7-1200 CPU 1212C and the PROFIBUS slave module, CM 1242-5.




5.2.2. Click on the CM 1242-5 module to carry out detailed configurations.

5.2.2.1. Assign a PROFIBUS address:




Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

5.2.2.2. Add I/O modules:




5.2.3. Next, you can compile and download this project to the S7-1200, and then click Go Online to run above settings on the S7-1200.

5.2.3.1. **Edit** → **Compile**:




Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

5.2.3.2. Online → Download to device:



5.2.3.3. Online → Go online:




6. Moxa's PROFIBUS device configuration


6.1. Install the GSD file

Before configuring the Moxa MGate 5101-PBM-MN, first install the relevant GSD file of the PROFIBUS slave device to allow the MGate 5101-PBM-MN to recognize the device.

- 6.1.1. Run MGate Manager and then click the **GSD Management** button to install the GSD file.




Click the **Add** button to select the location of the GSD file.




Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

Select the GSD file and then click the **Open** button to install it.




6.2. Device configuration with MGate Manager

6.2.1. Start MGate Manager and then **Search** for Moxa MGate 5101-PBM-MN.




6.2.2. Select the target device and click the **Configuration** button to configure it.



Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

6.2.3. Select the "PROFIBUS" tab and click the **PROFIBUS Settings** button to start PROFIBUS configuration.



6.2.4. Select **PROFIBUS** → **AutoScan** or click the **AutoScan** button to enable the AutoScan function to scan the PROFIBUS slave device automatically.



6.2.5. Check the appropriate checkbox to add the slave device to the PROFIBUS network:


Devices connected to the network							
<input checked="" type="checkbox"/>	Device status	Addr...	Ident...	Model name	Vendor	Module	GSD file
<input checked="" type="checkbox"/>	Master in bus configuration	1	0x0DF3	Moxa PROFIBU...	Moxa Inc.	-	MPBMODF3.gsd
<input checked="" type="checkbox"/>	Slave not in bus configuration	2	0x818E	CM 1242-5	SIEMENS AG	1 Word Output 1 Word Input	si01818E.gsd

Next, click the **OK** button. The MGate 5101-PBM-MN will complete the configuration for you.

6.2.6. After confirming that everything is correct, select **File** → **Save** to save the configuration and **File** → **Exit** to exit the "PROFIBUS Settings" window.

Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200


6.2.7. From the main window, click the **OK** button to save your modifications. The MGate 5101-PBM-MN will reboot, at which time the new configurations will be activated.



7. Communication Test

7.1. Execute Modbus Poll as the Modbus TCP master device

7.1.1. Execute the Modbus Poll on the PC to simulate the Modbus TCP master to exchange data with the MGate 5101-PBM-MN.





After the Modbus TCP connection is established, the application is ready.

Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

7.2. Modifying and monitoring I/O data


7.2.1. After making the above settings, the MGate device should work in a Modbus TCP / PROFIBUS environment. For example, we can use Modbus Poll to write or read data from the S7-1200 via the MGate 5101-PBM-MN.


7.2.2. Double click on the value of address 40001, input 0x1111, and then click the **Send** button to write the new value to the S7-1200. The value of the Input module should change automatically.





Moxa Tech Note PROFIBUS Configuration for Moxa MGate 5101 -PBM-MN and Siemens S7-1200

7.2.3. Input 0x2222 in the **Force value** column in TIA Portal V11 and click the

Force button  to output the new value to Modbus Poll address 40001.



	i	Name	Address	Display format	Monitor value	Force value	F
1		*Input*:P	%IW1:P	DEC_unsigned	1111		<input type="checkbox"/>
2		*Output*:P	%QW1:P	DEC_unsigned		2222	<input checked="" type="checkbox"/>
3		<Add new>					<input type="checkbox"/>



The above test confirms that the MGate 5101-PBM-MN will poll the PROFIBUS slave device regularly.